

**ERRATA**  
to the 2024 Edition of the  
**Wood Frame Construction Manual (WFCM) for One- and Two-Family Dwellings**  
(web version dated Nov. 27, 2023 )

**Page Revision**

65 Replace Footnote 4 in Table 2.2C as shown below in strike-out and underline.

- 4 Tabulated outlooker uplift connection loads are calculated using C&C pressure coefficients assuming a roof pitch range greater than 1.5:12 and less than or equal to 6:12. For roof pitches greater than 6:12, tabulated values are permitted to be multiplied by ~~0.86~~ 0.75.

**Page Revision .**

237 Replace Table 3.17E with the following table (no change in footnotes).

**Table 3.17E Perforated Shear Wall Full Height Sheathing Adjustments**

	Total Area of All Openings as a Percentage of Total Perforated Shear Wall Area																					
	0%	2%	4%	6%	8%	10%	13%	15%	18%	21%	25%	29%	33%	38%	44%	50%	57%	65%	75%			
<b>Total Length of Required Individual Full-Height Wall Segments (from Tables 3.17A, or 3.17C) as a Percentage of Total Perforated Shear Wall Length</b>	<b>Perforated Shear Wall Length Adjustment Factor<sup>1,2,3</sup></b>																					
10%	1.00											1.10	1.27	1.47	1.67	1.90	2.17	2.50				
15%	1.00											1.02	1.16	1.34	1.55	1.76	2.01	2.29	-			
20%	1.00											1.09	1.24	1.43	1.65	1.88	2.14	-	-			
25%	1.00											1.16	1.32	1.52	1.76	2.00	-	-	-			
30%	1.00											1.07	1.24	1.41	1.63	1.89	-	-	-			
35%	1.00											1.15	1.34	1.52	1.75	-	-	-	-			
40%	1.00											1.05	1.25	1.45	1.65	-	-	-	-			
45%	1.00											1.15	1.36	1.58	-	-	-	-	-			
50%	1.00											1.08	1.26	1.50	-	-	-	-	-			
55%	1.00											1.20	1.40	-	-	-	-	-	-			
60%	1.00											1.13	1.36	-	-	-	-	-	-			
65%	1.00											1.11	1.29	-	-	-	-	-	-			
70%	1.00											1.30	-	-	-	-	-	-	-			
75%	1.00											1.20	-	-	-	-	-	-	-			
80%	1.00											-	-	-	-	-	-	-	-			
85%	1.00											-	-	-	-	-	-	-	-			
90%	1.00											-	-	-	-	-	-	-	-			
95%	1.00	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
100%	1.00	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				

- 1 Full-height sheathing requirements in Tables 3.17A, or 3.17C shall be multiplied by the tabulated Perforated Shear Wall length increase factors to determine the required sheathing lengths for Perforated Shear Walls.
- 2 Shear Walls shall be blocked.
- 3 Interpolation of tabulated values is permitted.